Furnace			
	Model Number		
	Serial Number		
ELECTRICAL			
Line Voltage (Measure <b>L1 to N</b> and <b>N to Ground</b> Voltage)	L - N		
	N - G		
Secondary Voltage (Measure Transformer Output Voltage)	R - C		
Blower Amps	_		
BLOWER EXTERNAL STATIC PRESSURE			
Return Air Static Pressure		IN. W.C.	
Supply Air Static Pressure		IN. W.C.	
Total External Static Pressure (Ignoring +/- from the reading above, add total here)  TEMPERATURES	<u> </u>	IN. W.C.	
Return Air Temperature (Dry bulb / Wet bulb)		DB °F	WB °F
Cooling Supply Air Temperature (Dry bulb / Wet bulb)		DB °F	WB °F
Heating Supply Air Temperature		DB °F	
Temperature Rise		DB °F	
Delta T (Difference between Supply and Return Temperatures)		DB °F	
GAS PRESSURES			
Gas Inlet Pressure		IN. W.C.	
Gas Manifold Pressure (Low Fire)		IN. W.C.	
Gas Manifold Pressure (High Fire)	<u> </u>	IN. W.C.	
Gas Type (NG) = Natural Gas / (LP) = Liquid Propane			
Additional Checks			
Check wire routings for any rubbing			
Check for kinked pressure switch tubing.			
Check flue elbow for alignment and clamp tightness.			
Check screw tightness on blower wheel.			
Check factory wiring and wire connections.			
Check product for proper clearances as noted by installtion instructions	_		
°F to °C formula: (°F - 32) divided by 1.8 = °C           °C to °F formula: (°C multiplied by	1.8) + 32 = °F		