Power Quality Consultants
your uninterruptable power source

P 1800 543 237 F 07 3892 6066
1/12 Lucy Street Moorooka QLD 4105
PO Box 142 Moorooka QLD 4105
E sales@powerqc.com.au W www.powerqc.com.au
ABN 40 524 572 269

# Liebert UPS with Micropod Bypass 220L
# 2200-3000VA
# Typical Connections

**Main Power Switch Board**

Power Point
Standard
15 amp GPO

15 amp Power Cord
**0639388**
(supplied by PQC)

**Transient Voltage Surge Suppression Unit (recommended)**

Liebert Micropod
**MP2-220L**

**To your loads**

Micropod
connector cables
(supplied)

Network Interface
Card **(option)**

UPS GXT3-3000RT

Battery Connector
Cable
(supplied with
Battery Module)

External Battery Module
**(option)**